

This document has been translated for informative purpose only.  
Original version in German. In any case of doubt the German version is valid.

## EC-CERTIFICATE OF CONFORMITY

**0672 - CPD - 0151**

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive - CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

### Compact laminates "RESOPLAN® F"

with the classification enclosed in this certificate

placed on the market by

**Resopal GmbH  
Hans-Böckler-Straße 4  
64823 Groß-Umstadt**

and produced in the factory

**Groß-Umstadt**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved bodies have performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA 1.4 of the standards

**EN 438-7 (04/2005)**

were applied and that the product fulfils all the prescribed requirements.


This certificate was first issued on 10. November 2006 and remains valid as long as the conditions laid down in the harmonised technical specifications in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Stuttgart, 10. November 2006


Materials Testing Institute – University of Stuttgart  
Department of Mineral Construction Materials  
Certification Body

i.V.

(Akad. Oberrat, Dr. Stefan Lehner)  
Head of the Certification Body







## Enclosure to EG-CERTIFICATE OF CONFORMITY 0672 – CPD – 0151

The product compact laminates “RESOPLAN® F” is classified in the reaction to  
fire performance class:

**B-s2, d0**

Does apply to the following field of application:

- a thickness of the HPL-board of  $\geq 6$  mm.
- a density of the HPL-board of approx.  $1400 \text{ kg/m}^3$ .
- a mechanical fixing of the HPL-board on substructure out of squared timber or metal profiles.
- a in- and outdoor use of the HPL-board.
- optionally, as well backed with substrates of Euroclasses A1 and A2 with density  $\geq 50 \text{ kg/m}^3$  and thickness  $\geq 6$  mm of the HPL-board.

Stuttgart, 10. November 2006

Materials Testing Institute – University of Stuttgart  
Department of Mineral Construction Materials  
Certification Body

i.v.

(Akad. Oberrat, Dr. Stefan Lehner)  
Head of the Certification Body

